

Water Report October 2026

9/1/26	Replace water service lines at 371 & 387 E. Beaver St (copper @ customers)
9/3/26	Deleted 2" water main and meter pit on Centre St for 1023,1025 Airport Rd
9/4/26	Hydro excavate water main @ 1251 Parkwood Dr for locate
9/8/26	Leak detection 700 block of E. Curtin St
9/9/26	Dug up leak @ 704 E. Curtin St (clamp)
9/10/26	Dug up sink hole at Curtin St / Spring St (broken storm pipe)
9/11/26	Leak detection Benner Pike
9/14/26	Repair leak @ High St/ Oak Ln (bell joint repair)
9/14/26	Replace service line @ 987 E. High St (galvanized customers side)
9/15/26	Leak detection with L.B. Water on Benner Pike
9/16/26	Dug up 2 locations for insertion valves on 700 block of E. Curtin St
9/17/26	6" insertion valve @ Curtin St / Simpson St
9/18/26	6" insertion valve @ 722 E. Curtin St
9/21/26	Repair water main at 704 E. Curtin St
9/23/26	Repair 6" water main @ 2892 Benner Pike (clamp)
9/24/26	Replace service line @ 401 E. Beaver St (copper both sides)
9/24/26	Repair 6" water main leak @ Zion Rd / Center St (clamp) Replace service line @ 325 E. Burnside St (copper both sides)
9/29/26	Replace service line @ 727 W. Lamb St (copper customers side)
9/30/26	Repair leaking bell joint @ Willowbank St / W. Water St

Replaced 71 water meters

Marked 69 PA-1 Calls